

FINAL REPORT

Report ID : 245957

Report Information

Submitting Organisation : 00121321 : PENETRON AUSTRALIA
Account : 142341 : Penetron Australia
AWQC Reference : 142341-2018-CSR-1 : Prod Test: Penetron - Crystalline Waterproofing Coating
Project Reference : PT-3687
Product Designation : Penetron (Crystalline Coating Material)
Composition of Product : Cementitious - Crystalline Waterproofing Material.
Product Manufacturer : Penetron International, Pennsylvania, UNITED STATES of AMERICA.
Use of Product : In-Line/Concrete Waterproofing.
Sample Selection : As provided by the submitting organisation.
Testing Requested : **AS/NZS 4020:2005 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**
Product Type : Composite
Samples : Samples were prepared and controlled as described in Appendix A of AS/NZS 4020:2005
Extracts : Extracts were prepared as described in Appendix C, D, E, F, G, H.
Project Completion Date : 26-Feb-2019
Project Comment : The results presented herein demonstrate compliance to AS/NZS 4020 for Penetron (Crystalline Coating Material) at 20°C ± 2°C, exposed at an area to volume ratio up to 15,000 mm²/L.

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER



Michael Glasson
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025